

APPLICATIONS OF DIGITAL AND OPTOELECTRONIC CIRCUITS TO ELECTROTHERMAL-CHEMICAL GUN SYSTEM FACILITIES

G. L. Katulka
M. DelGuercio
T. Khong

Propulsion and Flight Division
Weapons Technology Directorate
U.S. Army Research Laboratory
Aberdeen Proving Ground, MD 21005-5066

Abstract

The use of digital electronic and optical electronic circuits for controlling various aspects of pulse-forming networks (PFNs) in electrothermal-chemical (ETC) gun facilities at the U.S. Army Research Laboratory (ARL) is described. A design of a digital sample and hold circuit used to retain, in digital memory, the initial voltage (and energy) of PFNs is considered. In addition, various uses of optical electronic circuits to control PFN safety network function, amplifier operations, and power supply switching are described.

Background

ETC gun systems are a novel propulsion concept that requires the injection of an electrical plasma into a propellant chamber to initiate and perhaps control the interior ballistic combustion process. The plasma is generated in a specialized chamber that consists of a small diameter fuse wire connecting the output terminals of a PFN. The plasma is intended to interact with stored propellant in the adjacent combustion chamber of the gun. The typical ETC laboratory system consists of several major subsystems, including a high-voltage power supply, PFN, switches, high-power coaxial cable, plasma cartridge, working fluid chamber, and a gun tube. The Weapons Technology Directorate (WTD) of the ARL employs several pulsed-power facilities in support of ETC (and electromagnetic) gun technology. All such facilities incorporate capacitor-based PFNs that are typical of the configuration shown in Figure 1. These networks discharge through high-power switches in a very short time frame (1–4 ms typically). The capacitors in this circuit have an electric charge placed on their terminals with an external DC power supply. Typically, systems operate at a maximum initial voltage of about 10–20 kV. Usually, this correlates to initial PFN energy levels in the range of hundreds of kilojoules or more. The PFN discharge and resulting plasma are initiated by the closure of the circuit switches which begins the flow of electrical current to the fuse wire located in the plasma gun chamber. More technical details of the PFN can be found in other publications [1, 2, 3, 4, 5, 6]. The electrical plasma is formed on the inside of a cylindrical cartridge which is in the form of a polyethylene capillary. As power from the PFN continues to feed the plasma, there is a tremendous increase in the temperature and internal pressure of the cartridge. Due to the large pressure gradient, plasma is ejected from the nozzle at the muzzle end of the capillary into the working fluid chamber where the combustion process is initiated. It is important to note, however, that the initial energy of the system is equal to one half the total capacitance multiplied by the square of the initial capacitor voltage. This relation is shown in Equation 1.

$$E = 1/2 \cdot C \cdot V^2 \quad (1)$$




Figure 1. Diagram of typical ETC PFN with safety network in place.

Also, it has been demonstrated by Tran and Wren of the ARL that total plasma-dissipated energy and mass are most sensitive to changes in initial capacitor voltage [7]. For these reasons, it is very desirable to know the initial capacitor voltage of the PFN to a high degree of accuracy. A technique that accomplishes this through the use of standard digital voltmeters and a triggerable latching circuit, which was designed at the ARL, is described within.

Another concern in the ETC laboratory is that of electrical isolation of personnel and equipment. Electrical isolation is a serious problem due to the very high electric potentials involved in operating PFNs for ETC applications. Most PFNs are capable of delivering very large amounts of electrical energy in a short time. Consequently, a tremendous peak power capability is inherently built into the ETC facility. With this in mind, it is important to utilize control systems for PFN operations that will allow for safe control of the PFN components with respect to electrical hazards. One obvious choice for electrical isolation of PFN controls is in the use of optical electronics and fiber-optic transmission links. The design of a particular optoelectronic circuit used for PFN safety relay control is described here. For this application, PFN relays are used as a means for discharging initially charged PFN capacitors to a safety network that will bleed off the stored energy over a longer time frame (see Figure 1). Such a situation will occur if it is decided to abort the gun firing after the PFN is energized. In this case, the alternate safety resistors or "dump" resistors are used to dissipate the initial PFN energy. The resistors are switched into the PFN capacitor circuit via the deactivation of the high-voltage relays, which are of the normally closed type (i.e., shorted when deactivated). The method of controlling the safety relay through an optical control circuit is also described. Finally, it is explained how components such as uninterruptible power supplies and charge amplifiers can be controlled with similar optoelectronic approaches. These methods will alleviate the problem of operators contacting high-voltage (and possibly high-energy) devices while working with the PFNs.

Digital Sample and Hold Circuit

For simplicity, Protek Model D-990 digital volt-ohm meters (DVOM) are used to measure initial capacitor voltage in the PFN circuit. These meters are convenient since they already contain an analog-to-digital (A/D) converter, a bar graph-integrated circuit, a 3.5-digit, 7-segment display, and they are of a reasonable cost. In the schematic diagram (Figure 2), it can be seen that when pin No. 57 is of a low state (i.e., grounded through manual switch s3), the A/D converter is placed in a memory or a "hold" mode.

In this state, the meter retains the last digital information that was sampled by the A/D prior to the closure of switch s3. For this application, the A/D converters are used to sample (at a rate of two times per second) the initial PFN capacitor voltage as measured through a 1,000:1 voltage divider (Fluke Model No. 80k). The instant the PFN begins to discharge to the circuit load, the converter must be transferred to the hold mode by the actuation of switch s3. In this manner, the voltage of the PFN just prior to discharge will be retained in the memory of the DVOM. To accomplish the automatic closure of switch s3 on the event initiation (i.e., PFN discharge), a TTL circuit was designed to provide power to a mechanical relay which takes the place of switch s3 (see Figure 3). The circuit consists of a set-reset (SR) latch (chip No. 4013), a 2N2222 NPN bipolar junction transistor, an LM44B00 magnetic relay, a 12-V power supply, and several 1/4-W resistors.

Report Documentation Page				Form Approved OMB No. 0704-0188	
Public reporting burden for the collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to a penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number.					
1. REPORT DATE JUN 1993		2. REPORT TYPE N/A		3. DATES COVERED -	
4. TITLE AND SUBTITLE Applications Of Digital And Optoelectronic Circuits To Electrothermal-Chemical Gun System Facilities				5a. CONTRACT NUMBER	
				5b. GRANT NUMBER	
				5c. PROGRAM ELEMENT NUMBER	
6. AUTHOR(S)				5d. PROJECT NUMBER	
				5e. TASK NUMBER	
				5f. WORK UNIT NUMBER	
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Propulsion and Flight Division Weapons Technology Directorate U.S. Anny Research Laboratory Aberdeen Proving Ground, MD 21005-5066				8. PERFORMING ORGANIZATION REPORT NUMBER	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)				10. SPONSOR/MONITOR'S ACRONYM(S)	
				11. SPONSOR/MONITOR'S REPORT NUMBER(S)	
12. DISTRIBUTION/AVAILABILITY STATEMENT Approved for public release, distribution unlimited					
13. SUPPLEMENTARY NOTES See also ADM002371. 2013 IEEE Pulsed Power Conference, Digest of Technical Papers 1976-2013, and Abstracts of the 2013 IEEE International Conference on Plasma Science. Held in San Francisco, CA on 16-21 June 2013. U.S. Government or Federal Purpose Rights License.					
14. ABSTRACT The use of digital electronic and optical electronic circuits for controlling various aspects of pulse-fonning networks (PFNs) in electrothennal-chemical (ETC) gun facilities at the U.S. Anny Research Laboratory (ARL) is described. A design of a digital sample and hold circuit used to retain, in digital memory, the initial voltage (and energy) of PFNs is considered. In addition, various uses of optical electronic circuits to control PFN safety network function, amplifier operations, and power supply switching are described.					
15. SUBJECT TERMS					
16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF ABSTRACT SAR	18. NUMBER OF PAGES 4	19a. NAME OF RESPONSIBLE PERSON
a. REPORT unclassified	b. ABSTRACT unclassified	c. THIS PAGE unclassified			




Figure 2. Schematic diagram of Protek Model D-990 digital meter.




Figure 3. Diagram of digital latching network.




Figure 4. Basic SR latch configuration: a) logic diagram; b) symbol; c) truth table.

The SR latch, a memory logic chip used to store binary information in digital systems, is used here as a temporary memory that can be set or reset depending upon the condition desired. In Figure 4, information is provided for a typical SR latch including the logic diagram, symbol, and the truth table. When the latch is set, pin No. 6 is in an active high state, and pin No. 2 (Q bar) output is in an active low state (see Figure 4). In this condition, the base of the NPN transistor is not drawing any current; therefore, the transistor remains nonconductive. If this is true, the resistance of the transistor as seen from collector to emitter is very large and, as a result, the LM44B00 relay cannot be energized or closed. With this condition present, the DVOM A/D converter is in the sampling or "live" mode and not in a hold condition. The DVOM will remain "latched" in this mode until the state of the SR latch is changed. Changing the state of the SR latch is accomplished by providing a pulsed signal to pin No. 4 (reset) of the chip.

The pulsed signal is taken from the trigger generator normally used to close the ignitron switches of the PFN. In this situation, the change in the state of the latch and the initiation of the DVOM hold mode correspond with the closure of the PFN ignitron switches. The end result is the storage of the PFN capacitor voltage to the memory of the DVOM fractions of a second prior to the PFN discharge. Under these conditions, operators can determine (via Equation 1, to approximately the accuracy of the voltmeters used) the initial energy of the PFN. To place the circuit

in the set state, a 12-V signal is applied to pin No. 6 via a push-button switch (see Figure 3). It should be noted that the 100-ohm resistors on pins No. 4 and No. 6 are used to keep those pins in the low state when the active high signals are not applied. Without these resistors, the electric potential of the latch may float high enough to change the state from low to high. This will cause random switching of the output states of the SR latch and will ultimately cause the DVOM to switch uncontrollably from live to hold mode. It should also be mentioned that the latch Integrated Circuit (IC) chip used here can serve as either an SR or Data (D) type latch. To operate in the SR latch mode, the clock must be kept in a high state while the D input is grounded.

Optoelectronic Controllers

Electrical isolation from high-voltage components of the PFN is a very important issue when dealing with systems that store large amounts of electrical energy as described here. Optoelectronic circuits provide a great deal of isolation and are inherently safer for operator use. One application of optoelectronics to control high-voltage discharge relays of a PFN, as shown in Figure 5, was designed at the ARL. In this arrangement, the optical circuit is used to activate, or open the circuit of, the PFN relays of the safety discharge network.





Figure 5. High-voltage relay optical control circuit.

This system consists of a Hewlett-Packard optical fiber, receiver Model 2524, transmitter Model 1523, and various other electronic components. The transmitter is made of a 660-nm light-emitting diode (LED) and has a peak forward current rating of 750 mA. The receiver includes a monolithic DC-coupled, digital IC receiver with an open collector Schottky output transistor. It has a maximum output current rating of 25 mA. The transmitter and receiver are displayed in Figure 6. A Schottky transistor is simply a rectifying device that contains a metal semiconductor junction [8]. The metal component allows electrons to move relatively unimpeded through the junction; therefore, the recombination time is quite fast (on the order of 10 ps), which makes this type of device of great value in high-speed applications [9]. For this particular application, high speed is not an issue since only DC control signals are used to change the states of the digital circuitry involved. An internal pullup resistor is available for use in the receiver if desired. This feature allows the output at Pin No. 4 to remain high, or "pull up" to the power supply voltage (5V) level when the transistor is not conducting. The transmitter and receiver are compatible with standard TTL circuitry, and a shield has been integrated into the receiver IC to provide additional, localized noise immunity. In the circuit of Figure 5, the base of the NPN transistor (2N2222) is grounded at pins No. 1 and No. 2 when the optical link is transmitting light. Electromagnetic radiation results in the movement of charge carriers through the photodiode in the optical receiver. This conduction current is amplified and applied to the base of an NPN (Schottky) transistor on the monolithically integrated receiver circuit. With current flowing to the base of the transistor, the resistance of the transistor from pin No. 2 to pin No. 1 is very small; thus, the large 2N2222 transistor remains at zero or ground potential. In this situation, the resistance as seen from points A to B on the 2N2222 is very large. This transistor acts as an open switch that impedes the flow of current from the 5-V power supply through the solid-state relay (Potter and Brumfield SSRT-120D10 Relay). The solid-state relay, which is now closed, connects the high-voltage relay coil to its 120-VAC power supply. Under these conditions, the high-voltage relay is energized (with open terminals), and the capacitors in the PFN can now be charged via an external DC power supply. Conversely, when the optical link is not transmitting light, the Schottky transistor offers a large impedance between pins No. 2 and No. 1 on the optical receiver. This effectively switches the base of the 2N2222 transistor from ground to the 5-V power supply (Vcc). Under this condition, the 2N2222 allows current to flow; thus, the solid-state relay is energized and in an open circuit position. The solid-state relay opens or removes power from the high-voltage relay coil. This condition causes shorting of the PFN capacitors through the high-voltage relay and the dump resistors. In this condition, the PFN is in a grounded or safe mode.

HFBR-152X/153X SERIES TRANSMITTER



HFBR-25X1/25X2/25X4 RECEIVER




Figure 6. Hewlett-Packard optical transmitter/receiver pair (HFBR 1523/2524).

For another optical control circuit design, the goal is to remotely ground and unground charge amplifiers. The diagram in Figure 7 shows the details of the system components. Dymec optical links, consisting of transmitter Model 6723 and receiver Model 6722 are needed to transmit a DC control signal to an LM44B00 magnetic relay. The relay is used to attach the charge amplifier to ground when a 5-V signal is applied to pins No. 1 and No. 2, as shown in Figure 7. Without the control signal applied, the charge amplifier is ungrounded. This system accomplishes the task of remotely preparing the charge amplifier to accept either a charge mode or a voltage mode transducer signal, and it allows the operators to stay completely clear from contacting any possible high-voltage component of the system.




Figure 7. Charge amplifier optical control circuit.

A system was designed that incorporates fiber optics for remotely controlling an uninterruptible power supply (UPS). Again, the optical approach is desired here for its capability of providing an excellent degree of electrical isolation. In this application, the Dymec optical link is used to control a solid-state relay (Potter and Brumfield SSRT-120D10). This relay is used to disconnect the UPS from the 120-VAC utility network so that it will begin to operate from the internal UPS battery supply. When power is not transmitted to the relay via the optical transmitter (located in the control room), the solid-state relay is inactive and in the normally closed position. Thus, the UPS is not in the battery power mode; instead, it is operating in the line power mode (see Figure 8).




Figure 8. Uninterruptible power supply optical control circuit.

Summary and Conclusions

Several criteria that exhibit the need for various digital and optoelectronic devices in the laboratory environment of the experimental ETC diagnostics facility were discussed. One need identified is in the form of a device that can store the initial voltage measured on PFN capacitors prior to an ETC gun firing. As a result, a digital circuit was designed to accomplish this task. This particular system was designed at the ARL using a digital-memory integrated circuit chip and other electronic components. This device is currently in operation at several ETC facilities at the ARL. In addition, optical electronic circuits and fiber-optic links have been designed and incorporated into the ETC facilities for purposes of remotely controlling PFN components. The addition of optical control circuits has greatly increased the electrical isolation of high-voltage components; therefore, the risk of electrical safety problems has been greatly decreased. Specific applications of optical circuits used in the ETC laboratory environment include high-voltage relays, charge amplifiers, and UPS control systems.

References

- [1] S. W. Bunte, R. A. Beyer, and A. E. Zielinski, "Temperature Measurements of ET Plasmas Using Atomic Emission Spectroscopy," BRL-TR-3196, U.S. Army Ballistic Research Laboratory, Aberdeen Proving Ground, MD, February 1991.
- [6] C. R. Hummer, K. T. A. Mahan, and C. E. Hollandsworth, "A Test Circuit for Capacitor Bank Grounding Sticks," BRL-TR-3980, U.S. Army Ballistic Research Laboratory, Aberdeen Proving Ground, MD, June 1992.
- [8] R. C. Jaeger, Introduction to Microelectronic Fabrication (Modular Series on Solid State Devices). Cleveland, OH: Addison-Wesley Publishing Company, Inc., 1988.
- [3] G. L. Katulka, H. Burden, A. Zielinski, and K. White, "Electrical Energy Shaping for Ballistic Applications in Electrothermal Guns," BRL-TR-3304, U.S. Army Ballistic Research Laboratory, Aberdeen Proving Ground, MD, December 1991.
- [2] T. Pfenning, C. Marinos, M. Hendrickson, and J. Hargreaves, "Mobile Pulse Power Systems for Electric Gun Tests." CPIA Publication 573, vol. 3, pp. 183-185, November 1991.
- [5] J. Powell, and A. E. Zielinski, "Theory and Experiment for an Ablating-Capillary Discharge and Applications to Electrothermal-Chemical Guns," BRL-TR-3355, U.S. Army Ballistic Research Laboratory, Aberdeen Proving Ground, MD, June 1992.
- [9] C. J. Savant, M. S. Roden, and G. L. Carpenter, Electronic Circuit Design. Meno Park, CA: The Benjamin/Cummings Publishing Company, Inc., 1987.
- [7] P. K. Tran, and G. P. Wren, "A Coupled Power-Plasma Model and Applications to Electrothermal-Chemical Guns," BRL-TR-3342, U.S. Army Ballistic Research Laboratory, Aberdeen Proving Ground, MD, May 1992.
- [4] A. E. Zielinski, and C. V. Renaud, "Erosion Resistance of CuNb Microcomposites in a Plasma Armature Electromagnetic Launcher," BRL-TR-3311, U.S. Army Ballistic Research Laboratory, Aberdeen Proving Ground, MD, January 1992.